

Passive Fire Protection Collar for Plumbing Service Penetrations

[View miproducts listing](#)



Level of assurance needed to demonstrate NZ Building Code Compliance

Supporting documentation should include technical information by manufacturer and either a BRANZ or independent Appraisal or CodeMark



Allproof confirms that this minimum level of assurance has been met or exceeded by the following:

Independently Tested

[Independently Tested - See Tech Literature](#)

masterspec partner

Company Contact Details

ALLPROOF
INDUSTRIES

Company: Allproof Industries

Physical Address: 17 Bay Park Place
Beach Haven
AUCKLAND

Postal Address: 17 Bay Park Place
Beach Haven
AUCKLAND

Telephone: 64 9 4818020

Fax: 64 9 4818021

Email: sales@allproof.co.nz

Website: www.allproof.co.nz

Technical Statement

Scope of use

Pipe collars are designed to be exposed in a wall or floor application (i.e. face fixed). The collars should always be fixed to the underneath of the concrete floor. In wall situations one collar should be used on each exposed side of the fire rated wall.

Allproof fire collars are to be installed only as tested. Please refer to Fire collar literature for test results and install drawings on Allproof's website allproof.com.

New Zealand Building Code (NZBC)

The product will, if employed in accordance with the supplier's installation and maintenance requirements, assist with meeting the following provisions of the building code:

- **Clause C3 Fire affecting areas beyond the fire source:** Performance C3.9
- **Clause C4 Movement to place of safety:** Performance C4.3

Notes

[C3.3 Buildings must be designed and constructed so that there is a low probability of fire spread to other property vertically or horizontally across a relevant boundary.](#)

All performance requirements stated by AS1530.4 - 2005 and AS4072.1 - 2005.

Evidence

The product meets the requirements set out in the following documents, or relevant parts of cited standards within the documents:

Please refer to our product and testing literature [here](#).

Supporting Evidence

The product has and can make available the following additional evidence to support the above statements:

Independently Tested

[Independently Tested - See Tech Literature](#)

Use in Service History

Allproof Fire collars are a highly respected product stocked in most plumbing merchants and are widely used by the industry.

Product Criteria

Design requirements

Please see installation guidelines in Allproof supporting documentation.

Installation requirements

Fire Collars must be installed as per Allproof supporting documentation. please view Allproof Fire Brochure for installation requirements.

Collars must be face fixed on wall or floors and must be installed using correct fixings as shown in literature.

Warrantees

Please see Allproof Warranty document [here](#).

Company Product Information

Allproof Fire Collar

Product Technical Statement: 108005



Relationships



New Zealand Made

Videos

[Allproof Passive Fire Intumescent Technology.](#)



Date last validated: **30 October 2019**



Date last updated: **30 October 2019**

Disclaimer: The Product Technical Statement (PTS) template is copyright to Construction Information Limited. However the content of this PTS is the responsibility of the product manufacturer/supplier. Refer to the miproducts Terms and Conditions